

# MINISTERO DELLA DIFESA

SECRETARIATO GENERALE DELLA DIFESA E DIREZIONE NAZIONALE DEGLI ARMAMENTI

*Direzione degli Armamenti Navali*

2<sup>a</sup> Reparto – 6<sup>a</sup> Divisione – 2<sup>a</sup> Sezione

“Servizio di sicurezza e impianti iperbarici, recipienti in pressione”

---

Si dichiara che l'impianto MARTEC AFSS, realizzato secondo quanto previsto dalla Tabella UMM 05.2.01 "IMPIANTO FISSO AUTOMATICO SOPPRESSIONE ESPLOSIONI AFSS", ha superato con successo le prove previste da tale norma con impiego di gas Halon e fluido "FK-5-1-12".

(riferimento al test report 4292 in data 17 marzo 2006 e 5497 in data 10 marzo 2008).

---

This is to confirm that Martec Automatic Fire Sensing and Suppression Systems (AFSS), complying with Italian Navy UMM 05.02.14 regulation, has successfully completed the performance tests required by said regulation using Halon gas and fluid "FK-5-1-12".

(reference is made to test report 4292 dated march 17, 2006 and 5497 dated march 10, 2008).

ROMA 16/3/2016

Firmato digitalmente da

IL DIRETTORE DELLA 6<sup>a</sup>DIVISIONE

CV Angelo Giuseppe CIRACI